

Version 3 Hammond Reef Gold Project EIS/EA – Addendum (Part B)
 Responses to Provincial Information Requests

1656263

Identifier	Topic	Reference to EIS/EA Report	Summary of Comment	Proponent's Response	Subsequent Comment
			<i>Date:</i>	<i>Date: December 2016</i>	
MNRF WTCM-4	Process Plant Collecting Pond, TMF Reclaim Pond "The operating volume within the pond below the spillway invert will be controlled by pumping."	Water Taking Contingency Measures, Section 1.4.1, 1.4.2	Where will this water be pumped (and treated)?	The volume of water in the TMF Reclaim Pond will be managed below the maximum operating volume by pumping water to the process plant for re-use or to the effluent treatment plant, located adjacent to the process plant, for treatment and release at the effluent discharge location.	